

Notification of Discharge of Untreated Wastewater

Moore County Public Works had a discharge of untreated wastewater from Lift Station 3-4 located at 2188 Longleaf Drive West in Pinehurst, North Carolina on September 16, 2018, of an estimated 70,500 gallons. The spill was due to Severe Natural Conditions (Hurricane Florence). The spill was reported on September 16, 2018 at 8:22 p.m. and continued for approximately 22 hours while repairs were made. The untreated wastewater entered an unknown tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on September 20, 2018 at 9:55 a.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.