

Notification of Discharge of Untreated Wastewater

Moore County Public Works had a discharge of untreated wastewater from Manhole MS-2-54 located at 85 Surry Circle North in Pinehurst, North Carolina on September 19, 2018, of an estimated 300 gallons. The spill was due to debris in the line. The spill was reported at 1:00 p.m. and continued for approximately 1 hour while repairs were made. The untreated wastewater entered Aberdeen Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on September 20, 2018 at 9:55 a.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.