

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater from our wastewater collection system at Lift Station PW-1 located at 10 Stoneykirk Drive, Pinehurst NC of approximately 15,326 gallons. The discharge occurred on March 2, 2017 and continued for approximately 3 hours while repairs were made. The untreated wastewater entered an unknown tributary to Joe Fork Creek. The discharge was due to pipe failure. The NCDEQ was notified of the event on March 3, 2017 at 8:40 a.m. and is reviewing the matter. For more information contact Moore County Public Works at (910)947-6315. This notice is required by North Carolina General Statutes Article 21, Chapter 143.215C.